

**Issued Monday, March 28, 2022**

**Number of pages: 1 typed, 0 Dwg.**

**Total = 1**

1

Specifications:

1. Refer to following Drawings.

Drawings:

1. Dwg. M001 Mechanical Schedules and Legend dated March 21, 2022 previously Issued for Addendum (#1).
2. Note the following for this Addendum # 2:
  1. Refer to the PLUMBING FIXTURE SCHEDULE on M001.
  2. Provide the following TRIM for L-1 and L-2 lavatories: Moen CA8301 or equivalent battery powered hands-free faucet, 0.5 gpm.
  3. Provide pressure-balanced mixing valve (with check valve and isolation valves) in service room and provide dedicated ½" tempered water lines from mixing valve to each lavatory. Valve to be rated for a minimum of 2.0 gpm.